



WIŚNIEWSKI

Declaration of Conformity

for industrial sectional doors

Manufacturer:
"WIŚNIEWSKI" Sp. z o.o. S.K.A.
PL 33-311 Wielogłowy 153

Declaration No.: 236/2012

"WIŚNIEWSKI" Sp. z o.o. S.K.A declares, that the weighted sound reduction index R_w and spectrum adaptation terms C and C_{tr} according to the standards:

PN-EN ISO 717-1:1999 Acoustics - Rating of sound insulation in buildings and of building elements - Part 1: Airborne sound insulation
is as follows:

MakroPro, Makro Pro INVEST, MakroPro 100
Test report No. GLA-1080.3/12

$R_w(C; C_{tr}) = 23 (-2, -3) \text{ dB}$

MakroPro, Makro Pro INVEST, MakroPro 100 with wicket door
Test report No. GLA-1080.1/12

$R_w(C; C_{tr}) = 24 (-2, -3) \text{ dB}$

MakroPro Alu, MakroPro Alu INVEST, MakroPro Alu 100 with single pane
Test report No. GLA-1080.4/12

$R_w(C; C_{tr}) = 23 (-1, -3) \text{ dB}$

MakroPro Alu, MakroPro Alu INVEST, MakroPro Alu 100 with double pane
Test report No. GLA-1080.5/12

$R_w(C; C_{tr}) = 23 (-1, -2) \text{ dB}$

MakroPro Alu, MakroPro Alu INVEST, MakroPro Alu 100 with double pane
and wicket door
Test report No. GLA-1080.2/12

$R_w(C; C_{tr}) = 25 (-1, -3) \text{ dB}$

UniTherm, PRIME, MakroPro XXL
Test report No. GLA-1080.6/12

$R_w(C; C_{tr}) = 24 (-1, -3) \text{ dB}$

**Authorized Certifying Organization
Group of Testing Laboratories GRYFITLAB**

ul. Prosta 2, Łozienica
72-100 Goleniów
Certificate of accreditation No. AB 818

„WIŚNIEWSKI” Sp. z o.o. S.K.A.

mgr inż.  Dariusz Złocki
Dyrektor Biura Konstrukcyjnego i IT

.....
(signature of authorized person)



Wielogłowy 22.11.2012