



BUILDING RESEARCH INSTITUTE



AB 023

GROUP OF TESTING LABORATORIES

accredited by Polish Centre for Accreditation

Accreditation Certificate
No AB 023

**LABORATORIUM OKUĆ I ŚLUSARKI BUDOWLANEJ (LOW ITB)
61-819 Poznań, ul. S. Taczaka 12**

Tel. +48 61 853-76-29 Fax +48 61 853-78-33 e-mail: laboratorium@itb.poznan.pl

**EXTRACT FROM THE TEST REPORT No LOW02-1639/11/Z00OWN
AND THE TECHNICAL OPINIONS No OWN-OT-021/2011 AND OWN-OT-037/2011**

Evidence of testing

The Laboratory LOW ITB carried out tests of the products:

**Industrial and commercial steel roller doors of R1 SSP and
R1 SSG type and aluminium roller doors of R1 ASP
and R1 ASG type**

submitted by:

**KRISPOL Sp. z o.o.
ul. Budowlana 1
Psary Małe, 62-300 Września**

On the basis of the Test Report and the Technical Opinions it is hereby stated that

**Industrial and commercial roller doors of
R1 SSP, R1 SSG, R1 ASP and R1 ASG type
meet requirements corresponding to class 3 of
resistance to manual burglary attempts
according to PN-ENV 1627:2006 and PN-EN 1627:2011***

.....

Poznań, December 29th, 2011

KIEROWNIK
Oddziału Wielkopolskiego
Instytutu Techniki Budowlanej

.....
mgr inż. Wojciech Kujawski

* provided that two locking devices are used, equipped with lock cylinders corresponding to minimum key related security grade 4 and attack resistance grade 1 according to PN-EN 1303:2007 and products are equipped with elements shown in photographs in Test Report, clause 1.1